

Test Report

Conical Mandrel Test

Report: 2022420022
Issued by: Mr. S. Meuwese
Date: November 3, 2022

Client: Recoat B.V.
Product: art. 87662 - Recoat 2K Floor One Plus 10:1

Test Method according to

ISO 6860 (ASTM D522)

CONTENTS

1.	TEST MATERIAL	page 2
2.	TEST EQUIPMENT	page 2
3.	TEST RESULTS	page 3

Copyright notice

The information in this report is protected by the Dutch Copyright Act and all copyrights are vested in Dercom. The distribution and reproduction of the information in this report without the prior written consent of Dercom is prohibited. © 2021 Dercom.

1. TEST MATERIAL

Coating:	Recoat 2K Floor One Plus 10:1	MFG:	Dercom B.V.
Batch no.:	N/A	Art. no.:	87662
Substrate:	Recoat Multi Primer	MFG:	Dercom B.V.

2. TEST EQUIPMENT

Substrate material:	Aluminum	Thickness:	1.2 mm (3/64 in.)
Substrate preparation:	Degreased with Recoat Cleaner		
Application:	Roller		

Copyright notice

The information in this report is protected by the Dutch Copyright Act and all copyrights are vested in Dercom. The distribution and reproduction of the information in this report without the prior written consent of Dercom is prohibited. © 2021 Dercom.

3. TEST RESULTS

Sample	Result
1	No defects
2	No defects
3	No defects
Average	No defects

Checked and approved by:



Mr. F. Derks
Laboratory R&D management

Our products are suitable for professional use only.

Registered processing times are valid under conditioned application circumstances only. In view of the many factors that may affect processing and application of our products, these data do not relieve processors from carrying out their own investigations and tests; neither do these data imply any guarantee of certain properties, nor the suitability of the products for a specific purpose. Any date, weights, proportions, etc. given herein are for general information purpose only; they may change without prior information and do not constitute the quality of the products (product specification). For technical support and advice with concern to choices of coatings systems and methods of application our technical staff will be at your service at all times.

Confidentiality

This report and the information therein is strictly confidential and is exclusively intended for the recipient of this report. The recipient of this report will keep all information in it strictly confidential and will not disclose, copy, reproduce or distribute any of it or otherwise make it available to any person or third party without the specific prior written consent of Dercom. The recipient of this report undertakes with Dercom that it will use any of the information in this report for internal purposes only.

Copyright notice

The information in this report is protected by the Dutch Copyright Act and all copyrights are vested in Dercom. The distribution and reproduction of the information in this report without the prior written consent of Dercom is prohibited. © 2021 Dercom.